

Chongnuo(Shandong) New Material Co., LTD

TEST REPORT

SCOPE OF WORK

vinyl (spc lvt) flooring

REPORT NUMBER

210517008SHF-003

TEST DATE(S)

2021-05-17 - 2021-06-02

ISSUE DATE

2021-06-02

PAGES


5

DOCUMENT CONTROL NUMBER

LFT-APAC-SHF-OP-10k(May 1, 2021)

© 2021 INTERTEK

Intertek Testing Services Shenzhen Ltd. Shanghai Fengxian Branch



Test Report

Statement

- 1.This report is invalid without company's special seal for testing on assigned page.
- 2.This report is invalid without authorized person's signature.
- 3.This report is invalid where any unauthorized modification indicated.
- 4.Don't copy this report in partial (except full copy) without any official approval in written by our company. This report is invalid without re-stamping the special seal for testing in copying report.
- 5.Any holder of this document is advised that this report is for the exclusive use of Intertek's Customer and is provided pursuant to the agreement between Intertek and its Customer. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. This report was made with due care within the limitation of a defined scope of work and on the basis of information, materials and instructions received from the Customer or its nominated third parties. Intertek is under no obligation to refer to or report upon any facts or circumstances which are outside the specific instructions received and accepts no responsibility to any parties whatsoever, following the issue of the report, for any matters arising outside the agreed scope of the works. The tests results are not intended to be a recommendation for any particular course of action. Customer is responsible for acting as it sees fit on the basis of such results.
- 6.Intertek's written consent is required to use Intertek's name or logo on the object, product or service being tested. The observations and test results in this report relate only to the sample under test. This report alone does not indicate that the item, product or service has passed any Intertek certification program.
- 7.The report was digital signed by Shang Hai, Intertek Group plc, please using Adobe Acrobat Reader to verify the authenticity.



Test Report

Issue Date: 2021-06-02 Intertek Report No. 210517008SHF-003
Applicant: Chongnuo(Shandong) New Material Co., LTD
Address: Northwest of the crossroad of Dongyue Street and Kunlun East Road, Economic Development Zone, Qingyun County, Dezhou City, Shandong Province
Attn: Lingling Xu
Test Type: Performance test, samples provided by the applicant.

Product Information

Product Name	vinyl (spc lvt) flooring	Brand	/
Sample Description	Good Condition	Sample Amount	25 pcs
		Received Date	2021-05-17
Sample ID	Model	Specification	
S210517008SHF.004	/	1220x183x4mm	

Test Methods And Standards

Test Standard	ISO 4918:2016/Amd.1:2018
Specification Standard	/
Test Conclusion	The samples were tested according to the above standards, and the results are shown in the following page.

Note:

1. This report relates specifically to the sample(s) that were drawn and provided by the applicant or their nominated third party. The reported result(s) provide no warranty or verification on the sample(s) representing any specific goods and/or shipment and only relate to the sample(s) as received and tested.

Report Authorized


Daniel Zhang Name: Daniel Zhang Title: Approver
Sally Xie Name: Sally Xie Title: Reviewer
Lillian Zhang Name: Lillian Zhang Title: Project Engineer

Test Report

Issue Date: 2021-06-02

Intertek Report No. 210517008SHF-003

Test Items, Method and Results:

Test Item: Castor chair test

Test Method: ISO 4918:2016/Amd.1:2018

Conditioning: Condition the test specimens at $(23 \pm 2)^{\circ}\text{C}$ and $(50 \pm 5)\%$ relative humidity for at least 24h

Test Condition: At a temperature range of 18°C to 25°C

Load mass: 90 kg
Test castors: Type W
Speed of rotating platform: 20 r/min
Speed of castor assembly: 50 r/min
Total test revolutions: 25000 r
Mounting of the specimen: Floating installation with click joints

Test Result:

Type of damage	Observation (Yes/No)	Verdict
Delamination	No	Pass
Opening of joints	No	
Surface damage	No	
Crazing	No	
Maximum opening	0.03mm	No requirement Report the result
Maximum height differences	0.08mm	

Test Photo:



After test

Test Report

Issue Date: 2021-06-02

Intertek Report No. 210517008SHF-003

Appendix A: Sample Received Photo



Front View(Test surface)



Back View

Revision:

NO.	Date	Changes
210517008SHF-003	2021-06-02	First issue